

PUBLIC HEALTH DIVISION, BETTIAH

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON 02/09/2026 BY Dr. Kumari Anjali & RECEIVED IN THE LABORATORY ON 02/09/2026

Sl. NO	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned)															
	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test	
14	Beltiah	Nagar Nigam	CHHAWANI	ST. Michael's Academy	0.90	7.3	241	94	102	24	8	15	10	<0.2	<1	0.2	161	NT	Neg.	
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5 8.5		200 600	200 600	75 200	30 100	250 1000	200 400	1.0 NR	45 NR	1 1.5	500 2000	0.01 NR	+VE -VE	

Remarks-- Analysed parameters of above sample is within permissible limit.

Memo No. 52, Dated: 05-09-2026

Anil Kumar
Signature of the Chemist
CHEMIST
DLWTL
P.H. Division, Bettiah

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: 54

Dated: 07.09.2026

It is certified that an inspection team headed by ANIL KUMAR (CHEMIST)

(Name of Officers with designation) from PHED, Bettiah PHED Inspected the

ST. MICHAEL'S ACADEMY, CHHAWANI, BETTIAH (Name & Address of the school) on

07.09.2026 (date of inspection) and on the basis of Water Test Report

(Attached) bearing no. 52 dated 05.09.2026 of

..... (PHED Lab) certified that the ST. MICHAEL'S ACADEMY, CHHAWANI,

BETTIAH has safe drinking water facilities for the students and members of staff of the

institution. School is also maintains the hygienic sanitation condition in the school building &

the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 06.09.2027

Signature with Seal: Anilkr.
07/09/2026

Name

: ANIL KUMAR

Designation

: CHEMIST

Name & Address of the Office/Department: PHED

Bettiah

To

St. Michael's Academy (English

Medium) Chhawani, Bettiah

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies